

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 603

Dated: 14.04.2026

It is certified that an inspection team headed by DR RENU KUHARI PRASAD

(Name of Officers with designation) from M.O.I CAMPATCHAK PHED inspected

the EDULETICS INTERNATIONAL A BRITISH SCHOOL, SUKULPUR, PUNADIH,

DEEDARGANJ, PATNA-803201 (Name & Address of the school) on 14.04.2026 (date

of inspection) and on the basis of Water Test Report (Attached) bearing no

STH/TR/25-26/05/116 dated 10.04.2026 of

OMSHIVA TEST HOUSE PRIVATE LIMITED (PHED Lab)

PATLIPUTRA COLONY PATNA BIHAR PIN-800013 certified that

the EDULETICS INTERNATIONAL A BRITISH SCHOOL (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School also maintains

the hygienic sanitation condition in the school building & the campus as per norms prescribed

by the Central/ State/ U.T. Govt.

This certificate is valid till 14.04.2026 to 13.04.2027

Signature with Seal:

Name

Designation

Name & Address of the Office /

Department :

To

EDULETICS INTERNATIONAL A BRITISH
SCHOOL,
SUKULPUR PUNADIH, DEEDARGANJ,
PATNA-803201 (Name & Address of the
Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Ashwin

MANAGER
EDULETICS INTERNATIONAL
A BRITISH SCHOOL

DEEDARGANJ SUKULPUR, NH-31, PATNA-803 201

Reshma Singh
21/05/2026

PRINCIPAL
EDULETICS INTERNATIONAL
A BRITISH SCHOOL

DEEDARGANJ SUKULPUR, NH-31, PATNA-803 201



OMSHIVA TEST HOUSE PRIVATE LIMITED

..... PROTECTING SINCE 1988

ESTING | CONSULTING | RESOLVING | TRAINING


Head Office :

122-C, Aastha, Road No. 5A,
Patliputra Colony,
Patna - 800 013 (Bihar)
Contact us : +918676886249
+919431047908
Email : coo@shivatesthouse.in
cao@shivatesthouse.in



TC-14261

OMSHIVA TEST HOUSE PVT LTD



STH/25/05/116

TEST REPORT

Name and Address of Customer :

EDULETICS INTERNATIONAL A BRITISH SCHOOL
DEEDARGANJ, SUKULPUR,
PATNA- 803201

Information by Customer :

Name / Nature of Sample : Drinking Water Sample
Location of Sampling (By Customer): From RO

W.O No.: NIL
WO Date: 05.05.2025

Laboratory Provided Details :

ULR Number STH/TR/25-26/05/116
Sample Received on 05.05.2025
Sample Quantity & Container 2 L., Polypropylene Bottle (02)
Sample Condition on Receipt Fit for analysis
Sample Collected by Sample provided by Customer

Analysis Details :


Sample Code STH/25/05/116
Analysis Start Date 05.05.2025
Analysis Completion Date 10.05.2025
Items required to be Tested As per request
Any Specific Test Method No
Reporting Date 10.05.2025
Report Prepared by S. K. Singh

ANALYSIS RESULTS

S.N.	Parameters	Unit	Method of Test	Limit as per IS 10500: 2012		Results
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Analysis						
1	pH at 25 ^o C	----	IS 3025 (Part-11)	6.5-8.5	No relaxation	7.29
2	Turbidity	NTU	IS 3025 (Part-10)	1.0 Max.	5.0	0.68
3	Total Dissolved Solids (TDS)	mg/L	IS 3025 (Part-16)	500.0 Max.	2000.00	401.0
4	Conductivity	µmhos/cm	IS 3025 (Part-14)	Not Specified		726.0
Chemical Analysis						
5	Total Hardness as CaCO ₃	mg/L	IS 3025 (Part-21)	200.0 Max.	600.00	234.0
6	Calcium as Ca	mg/L	IS 3025 (Part-40)	75.0 Max.	200.00	60.1
7	Magnesium as Mg	mg/L	IS 3025 (Part-46)	30.0 Max.	100.0	20.4
8	Residual Free Chlorine	mg/L	IS 3025 (Part-26)	0.2 Min.	1	<1.0
9	Total Alkalinity as CaCO ₃	mg/L	IS 3025 (Part-23)	200.0 Max.	600.00	292.0
10	Chloride as Cl	mg/L	IS 3025 (Part-32)	250.0 Max.	1000.00	17.0
11	Sulphate as SO ₄	mg/L	IS 3025 (Part-24)	200.0 Max.	400.00	24.9
12	Nitrate as NO ₃	mg/L	IS 3025 (Part-34)	45.0 Max.	No relaxation	1.78
13	Fluoride as F	mg/L	IS 3025 (Part 60)	1.0 Max.	1.5	0.18
Metal Analysis						
14	Arsenic as As	mg/L	STH/SOP/MET/SPW-002	0.01 Max.	No Relaxation	BLQ (LOQ-0.002)
15	Iron as Fe	mg/L	STH/SOP/MET/SPW-002	1.0 Max.	No Relaxation	0.10

BLQ= Below Limit of Quantification; LOQ= Limit of Quantification

MANAGER
EDULETICS INTERNATIONAL



PRINCIPAL
EDULETICS INTERNATIONAL

N.B.:

(1) This report applies only to the samples received at the Laboratory. (2) The Laboratory is limited to the amount of sample received. (3) Test Report endorsed by the Laboratory is valid only for the purpose of the test. (4) Test Report cannot be reproduced or used for any other purpose without written permission of the Laboratory. (5) The samples will be retained for a day after the test.

Branch:1 Uttarakhand : 410 Pratap Palace, 3rd Floor 26 & 27 Dehradun - 248001. Mob: +91 -9999505562

Branch:2 Uttar Pradesh: M.S.-1/10, Sector A, Silapur Road Yojna, Ram Ram Bank Chauraha, Lucknow-226021 Mob: +91 - 9336348520





OMSHIVA TEST HOUSE PRIVATE LIMITED

..... PROTECTING SINCE 1988

ESTING | CONSULTING | RESOLVING | TRAINING

Head Office :
122-C, Aastha, Road No. 5A,
Patliputra Colony,
Patna - 800 013 (Bihar)
Contact us : +918676886249
+919431047908
Email : coo@shivatesthouse.in
cao@shivatesthouse.in



TEST REPORT

OMSHIVA TEST HOUSE PVT LTD



STH/25/05/116

Continuation Sheet


ULR NUMBER.: STH/TR/25-26/05/116

ANALYSIS RESULTS

S.N.	Parameters	Unit	Method of Test	Limit as per IS 10500: 2012	Results
Microbiological Analysts					
16	Total Coliform	MPN / 100 ml	IS 1622	Not Specified	<2.0
NB:	Sample Collected by Customer & Results applied to the sample as received.				

Ashwin
MANAGER
EDULETICS INTERNATIONAL
A BRITISH SCHOOL
DEEDARGANJ SUKULPUR, NH-31, PATNA-803 201

Preshma Singh
31/05/2025
PRINCIPAL
EDULETICS INTERNATIONAL
A BRITISH SCHOOL
DEEDARGANJ SUKULPUR, NH-31, PATNA-803 201



Vishal Sharma

Reviewed by :
Vishal Sharma (DQM)

Chittaranjan Das

Authorized Signatory:
Chittaranjan Das, Sec. I/c (Food, Residue & Water Proximate, Trace Metals)

Piyali Das Sharma

Authorized Signatory :
Piyali Das Sharma, Sec. I/c (Mcb.)

Shreyasee Prasad

Quality Manager :
Dr. (Mrs.) Shreyasee Prasad

----- END OF REPORT -----

N.B.: (1) This report applies only to sample tested as above. (2) Total Liability of our Laboratory is limited to invoiced amount. (3) Test Report endorsed only the tests and not the product certificate. (4) Test Report cannot be reproduced partially or full for legal/court purpose without written permission of the Laboratory. (5) The samples will be retained for 3 days after the report generation.

Branch:1 Uttarakhand : 410 Pratap Palace, 3rd Floor 26 & 27 Dehradun - 248001, Mob: +91 -9999505562

Branch:2 Uttar Pradesh: M.S.-1/10, Sector A, Silapur Road Yojna, Ram Ram Bank Chauraha, Lucknow-226021 Mob: +91 - 9336348520

